

GILDED FROST TESTING

Test	UNIT	TEST METHODS	TEST RESULTS
Apparent Specific Weight	kg/m ³	Vietnamese Standard TCVN 1772-87	2721
Absorption Coefficient	%	Vietnamese Standard TCVN 6530-99 SECTION 3	0.11
Compressive Strength	kg/cm ²	Vietnamese Standard TCVN 6055-1:98	531
Modulus of Rapture	kg/cm ²	Vietnamese Standard TCVN 6355-1:98	182
Abrasion Resistance	mm	Vietnamese Standard TCVN 6885:2001	30.08